CERTIFICATE

Issued to: Applicant: Tyco Electronics Austria GmbH Schrackstrasse 1 3830 Waidhofen, Austria

Licensee:

Tyco Electronics Austria GmbH Schrackstrasse 1 3830 Waidhofen, Austria

Product	:	Connectors for DC-application in photovoltaic systems	
Trade name(s)	:	Solarlok 2.0 or TE Connectivity	
Type(s)/model(s)	:	SLK-zz-y-BL-XX	

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard(s) IEC 62852:2014 and EN 62852/2015
- an inspection of the factory location according to CENELEC Operational Document/CIG 021
- a DEKRA certification agreement with the number 6059800/

DEKRA hereby grants the right to use the DEKRA Seal certification mark.

The DEKRA Seal certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Seal certification agreement.

This certificate is issued on 3 June 2021 and expires at the latest on 3 June 2026.

Certificate number: 31-119033

DEKRA Certification B.V.

B.T.M. Holtus Managing Director

H.R.M. Barends Certification Manager

© Integral publication of this certificate is allowed



page 1 of 2

SPECIFICATION OF THE CERTIFIED PRODUCT

Trade name(s) :	Connectors for DC-application in photovoltaic systems Solarlok 2.0 or TE Connectivity SLK-zz-y-BL-XX
	1500 Vdc
0	30 A for 2,5 mm ²
	35 A for 4,0 mm ² 40 A for 6,0 mm ²
Ambient Temperature :	-40 ℃ to +85 ℃
Upper Limit Temperature :	+105°C
Cross Section Range :	1 x 2,5 mm² ;1 x 4,0 mm² ; 1 x 6,0 mm²
Protection Degree :	IP 65, IP 66 and IP 68(24 h, 1 m)
Application Class :	Class A

TESTS

Test requirements

IEC 62852:2014 EN 62852:2015

Test result

The test results are laid down in DEKRA test file 610087500.

Additional information

Type(s)model(s) description: SLK-zz-y-BL-XX zz: - PI = PV4-S pin to IDC - SK = PV4-S socket to IDC y: - 1 per package - 5 per package - 9 per package BL: - BL = Black XX: - XX = No fuse or Diode

The list of components is laid down in test report 6100875A.50.

Conclusion


The examination proved that all requirements were met.

Factory location Tyco Electronics EC Trutonv s.r.o. Komenskeho 821 541 83 Trutnov, Czech Republic



ANNEX TO DEKRA Type Approved Seal CERTIFICATE 31-119033

page 2 of 2



Unique Identifier

